

| R-VALUE<br>(hr•sq.ft.°F/BTU)                  | MINIMUM INSTALLED<br>THICKNESS (in.)             | SETTLED THICKNESS<br>(in.)                                      | BAGS PER 1,000 SQ. FT.                                     | MAXIMUM NET<br>COVERAGE<br>(sq.ft./bag)                | MINIMUM WEIGHT<br>(lbs./sq.ft.)   |
|---|--|---|--|--|---|
| To obtain an insulation<br>resistance (R) of: | Installed insulation<br>should not be less than: | Expected thickness<br>after long-term settling<br>has occurred: | Minimum number of<br>bags per 1,000 sq.ft.<br>of net area: | Contents of this bag<br>should not cover<br>more than: | The weight per sq. ft.<br>of installed insulation<br>should not be less than: |
| 11  | 4.25   | 4.25  | 4.6  | 215.9  | 0.15  |
| 13  | 5.00   | 5.00  | 5.5  | 181.3  | 0.17  |
| 19  | 7.00   | 7.00  | 8.0  | 125.4  | 0.25  |
| 22  | 8.00   | 8.00  | 9.3  | 108.0  | 0.29  |
| 26  | 9.50   | 9.50  | 11.2   | 88.9   | 0.35  |
| 30  | 10.75  | 10.75   | 13.0   | 77.1   | 0.41  |
| 38  | 13.50  | 13.50   | 17.0   | 59.0   | 0.53  |
| 44  | 15.25  | 15.25   | 19.6   | 50.9   | 0.62  |
| 49  | 17.00  | 17.00   | 22.4   | 44.6   | 0.71  |
| 60  | 20.25  | 20.25   | 27.9   | 35.8   | 0.88  |
| 64  | 21.50  | 21.50   | 30.0   | 33.3   | 0.95  |
| 68  | 22.75  | 22.75   | 32.3   | 31.0   | 1.02  |
| 70  | 23.25  | 23.25   | 33.2   | 30.1   | 1.05  |
| 72  | 24.00  | 24.00   | 34.6   | 28.9   | 1.09  |
| 76  | 25.00  | 25.00   | 36.5   | 27.4   | 1.15  |
| 80  | 26.25  | 26.25   | 38.9   | 25.7   | 1.22  |
| 84  | 27.50  | 27.50   | 41.3   | 24.2   | 1.30  |
| 88  | 28.50  | 28.50   | 43.4   | 23.1   | 1.37  |
| 92  | 29.75  | 29.75   | 45.9   | 21.8   | 1.45  |
| 96  | 30.75  | 30.75   | 48.0   | 20.8   | 1.51  |
| 100   | 32.00  | 32.00   | 50.7   | 19.7   | 1.60  |